



AdvantEx Final Discharge (Low-Head & High Head)



3'-0" Dia. Final Discharge
(Low-Head)

Low-Head	
Sump Volume	79 Gallons
Dose Volume	62 Gallons
Pump Failure to HW Alarm	13 Gallons



3'-0" Dia. Final Discharge
(High-Head)

High-Head	
Sump Volume	106 Gallons
Dose Volume	61 Gallons
Pump Failure to HW Alarm	14 Gallons